

# Certificate of Compliance



You have been awarded:

## Intertek ETL C + US Mark for Firestop Systems

Standards: ASTM E2307 (2015), CAN / ULC S115 (2018) Ed. 5

Certificate number: WHI19-23235504

**Organization:** Hilti Corporation  
Feldkircherstrasse 100  
FL-9494  
Schaan  
Principality of Liechtenstein

**Product:** Hilti Corporation - CFS-EOS QS Perimeter Fire Barrier System  
*Spec ID:* 49062  
**RATINGS**  
ASTM E2307  
CAN/ULC S115  
**CFS-EOS QS Perimeter Fire Barrier System**  
**ASTM E 2307 & CAN/ULC S115**  
**System Number F-Rating T-Rating**  
HI/BPF 120-18 2-Hour 33 Min  
HI/BPF 120-19 2-Hour 33 Min

**Certification body:** Intertek Testing Services NA, Inc.  
**Initial registration:** July 11, 2019  
**Date of expiry:** July 11, 2024  
**Issue status:** 1

This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Charles Meyers  
Certification Manager

Name

Signature

7/15/2019  
Date

Registered address:  
Intertek Testing Services NA, Inc. 545 E. Algonquin Rd. Arlington Heights, IL 60005 USA

[www.intertek.com](http://www.intertek.com)