

UL/cUL SYSTEM NO. C-AJ-8336


**MULTIPLE PENETRATING ITEMS THROUGH CONCRETE FLOOR/WALL
OR BLOCK WALL ASSEMBLY**

F-RATING = 1-HR. OR 2-HR.


T-RATING = 1/4-HR.

CAJ8336b.082124

BOTTOM VIEW



SECTION A-A



HILTI, Inc.
Plano, Texas USA (800) 879-8000

Sheet	1 of 2
Scale	3/16" = 1"
Date	Aug. 21, 2024

Drawing No.

**CAJ
8336b**

Saving Lives through Innovation and Education

MULTIPLE PENETRATING ITEMS THROUGH CONCRETE FLOOR/WALL OR BLOCK WALL ASSEMBLY

F-RATING = 1-HR. OR 2-HR.

T-RATING = 1/4-HR.

CAJ8336b.082124

1. CONCRETE FLOOR OR WALL ASSEMBLY (1-HR. OR 2-HR. FIRE-RATING) :
 - A. LIGHTWEIGHT OR NORMAL WEIGHT CONCRETE FLOOR OR WALL (MINIMUM 4-1/2" THICK).
2. PENETRATING ITEM (QTY. = 1) TO CONSIST OF ONE OF THE FOLLOWING :
 - A. MAXIMUM 3/4" NOMINAL DIAMETER COPPER PIPE OR TUBING.
 - B. MAXIMUM 3/4" NOMINAL DIAMETER CAST OR DUCTILE IRON PIPE.
 - C. MAXIMUM 3/4" NOMINAL DIAMETER STEEL CONDUIT OR STEEL EMT.
 - D. MAXIMUM 3/4" NOMINAL DIAMETER PIPE (SCHEDULE 5 OR HEAVIER).
3. MAXIMUM 7/8" NOMINAL DIAMETER COPPER PIPE OR TUBING WITH MAXIMUM 3/4" THICK LOW DENSITY POLYETHYLENE (LDPE) FLEXIBLE FOAM PIPE INSULATION (MANUFACTURED BY PDM US LLC - GELCOPPER OR GELBLACK) (MAX. QTY. = 1).
4. MAXIMUM 4 PAIR NO. 18 AWG THERMOSTAT CABLE WITH PVC JACKET (MAX. QTY. = 1).
5. HILTI CP 648E WRAP STRIP (NOMINAL 3/16" THICK x 1-3/4" WIDE) CONTINUOUSLY WRAPPED AROUND THE OUTER CIRCUMFERENCE OF THE THE PENETRATING ITEMS, COVERING TWO TIMES, WITH ENDS BUTTED AND HELD IN PLACE WITH TAPE. WRAP STRIPS RECESSED FROM TOP SURFACE OF THE FLOOR TO ACCOMMODATE FIRESTOP SEALANT.
6. MINIMUM 1/2" DEPTH HILTI FS-ONE MAX INTUMESCENT FIRESTOP SEALANT.

NOTES : 1. MAXIMUM DIAMETER OF OPENING = 4".
 2. ANNULAR SPACE BETWEEN PENETRANTS AND PERIPHERY OF OPENING = MINIMUM 3/8", MAXIMUM 1-1/2".
 3. PENETRANTS THROUGH OPENING TO BE TIGHTLY BUNDLED TOGETHER.
 4. HILTI FS-ONE MAX INTUMESCENT FIRESTOP SEALANT TO BE APPLIED INTO INTERSTICES OF BUNDLE TO MAXIMUM EXTENT POSSIBLE.
 5. HILTI CP 648E WRAP STRIPS AND HILTI FS-ONE MAX INTUMESCENT FIRESTOP SEALANT ARE REQUIRED ON BOTH SIDES OF A WALL ASSEMBLY.



Hilti Firestop Systems

HILTI, Inc.
 Plano, Texas USA (800) 879-8000

Sheet	2 of 2
Scale	-
Date	Aug. 21, 2024

Drawing No.

CAJ
8336b

Saving Lives through Innovation and Education