




Classified by
Underwriters Laboratories, Inc.
to UL 1479 and CAN/ULC-S115

System No. W-J-1067

WJ 1067

ANSI/UL1479 (ASTM E814)	CAN/ULC S115
F Ratings — 1 and 2 Hr (See Items 1 and 3)	F Ratings — 1 and 2 Hr (See Items 1, 2 and 3)
T Ratings — 0 and 1/2 Hr (See Item 2)	FT Rating — 0 Hr
L Rating At Ambient — Less Than 1 CFM/sq ft	FH Rating — 1 and 2 Hr (See Items 1 and 3)
L Rating At 400 F — Less Than 1 CFM/sq ft	FTH Rating — 0 Hr
	L Rating At Ambient — Less Than 1 CFM/sq ft
	L Rating At 400 F — Less Than 1 CFM/sq ft



SECTION A-A

1. Wall Assembly — Min 3-3/4 in. and 5 in. (95 and 127 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete for 1 and 2 h rated assemblies, respectively. For Items 2F and 2G, min 6 in. (152 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete. Wall may also be constructed of any UL Classified Concrete Blocks*. Max diam of opening is 32-1/4 in. (819 mm).

See Concrete Blocks (CAZT) category in the Fire Resistance Directory for names of manufacturers.



Hilti Firestop Systems

Reproduced by Hilti, Inc. Courtesy of
Underwriters Laboratories, Inc.
December 19, 2025

2. Through—Penetrants — One metallic pipe, conduit or tubing to be installed either concentrically or eccentrically within the firestop system. The annular space for Penetrants 2A to 2F shall be min 0 in. to max 2-1/4 in. (57 mm). These pipes/tubings may be installed with continuous point contact. The annular space for Penetrants s 2G and 2H shall be min 0 in. to max 1-1/2 in. (38 mm). Pipe, conduit or tubing to be rigidly supported on both sides of wall assembly. The following types and sizes of metallic pipes, conduits or tubing may be used:

- A. Steel Pipe — Nom 30 in. (762 mm) diam (or smaller) Schedule 10 (or heavier) steel pipe.
- B. Stainless Steel Pipe - Nom 30 in. (762 mm) diam (or smaller) Schedule 10 (or heavier) stainless steel pipe.
- C. Iron Pipe — Nom 30 in. (762 mm) diam (or smaller) cast or ductile iron pipe.
- D. Conduit — Nom 4 in. (102 mm) diam (or smaller) steel electrical metallic tubing or 6 in. (152 mm) diam (or smaller) steel conduit.
- E. Copper Tubing — Nom 6 in. (152 mm) diam (or smaller) Type L (or heavier) copper tubing.
- F. Copper Pipe — Nom 6 in. (152 mm) diam (or smaller) Regular (or heavier) copper pipe.
- G. Aluminum Pipe — Nom 2 in. (51 mm) diam (or smaller) Schedule 5 (or heavier) aluminum pipe for use in closed (process or supply) piping systems.
- H. Aluminum Conduit — Nom 2 in. (51 mm) diam (or smaller) aluminum electric metallic tubing (EMT) or rigid aluminum conduit for use in closed (process or supply) piping systems.

The hourly T and FT Ratings of the firestop system are equal to 0 Hr when Penetrants s 2A to 2F are used. The hourly T Rating is equal to 1/2 Hr when Penetrants s 2F and 2G are used.

Certification to CAN/ULC -S115 is limited to Penetrants A (Steel Pipe), B (Stainless Steel Pipe), C (Iron Pipe), D (Conduit), E (Copper Tubing), and F (Copper Pipe).

3. Fill, Void or Cavity Material* — Min 5/8 in. (16 mm) thickness of fill material applied within the annulus, flush with both surfaces of wall. At the point or continuous contact locations between pipe and wall, a min 1/2 in. (13 mm) diam bead of fill material shall be applied at the pipe-wall interface on both surfaces of wall.

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — FS-ONE MAX Intumescent Sealant

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.